

STANDARD INSTALLATION

OPTIONAL DIL ABSORBENT SOCK AVAILABLE UPON REQUEST.



NOTES:

1. SUMP DEPTH DEPENDENT ON DESIRED STORAGE CAPACITY. MINIMUM OF 12'FROM INVERT OF PIPE, RECOMMENDED 24' DEEP.




- GENERAL NOTES:

 1. ALL MATERIALS MADE OF HEAVY DUTY POLYETHALINE PLASTIC.
- 2. LIGHT WEIGHT DESIGN FOR EASE OF HANDLING
- 3, THE SURFACE OF THE STRUCTURE WHERE THE UNIT WILL BE MOUNTED IS TO BE SMOOTH AND FREE OF LOOSE MATERIAL.
- 4. THE BOTTOM OF THE UNIT SHOULD EXTEND A MINIMUM OF 6' BELOW THE INVERT OF THE OUTLET PIPE
- 5. THE HOOD SHOULD BE SECURELY ATTACHED TO THE STRUCTURE W/ PROVIDED HARDWARE PER INSTALLATION INSTRUCTIONS.
- 6. REFER TO INSTALLATION INSTRUCTIONS FOR SPECIFIC INSTALLATION DETAILS.
- 7. ENVIROTRAP TO INCLUDE FILTER FRAME & PACK WITH 10PPM HYDROCARBON REMOVAL EFFICIENCY. ALSO REQUIRED TO BE SUPPLIED WITH AN OIL ABOSORBENT MATERIAL.
- 8. ALL ENVIROTRAP UNITS ARE TO BE SUPPLIED BY ENVIRONMENT 21, LLC OR AN APPROVED REPRESENTATIVE.
- 9. ALSO AVAILABLE FOR ATTACHMENT IS A FLOW RESTRICTOR AND FILTER MEDIA ATTACHMENT.
- 9. ENVIROTRAP HAS A PATENT PENDING.
- 10. GROSS POLLUTANT TRAP- CAPTURES HYDROCARBONS, COARSE SEDIMENT, AND FLOATABLES

INSTALLATION DETAIL

SHOWN WITHOUT FLOW DIFFUSER



ENVIRONMENT 21, LLC STORMWATER TREATMENT SYSTEMS

"ENVIROTRAP" WITH DIL FILTER PANEL AND FRAME

1-800-809-2801

SIZE FSCM NO. DWG NO.

ENVTRAP-DIL

REV

www.ENV21.com

environment\

SCALE

SHEET